

# Termoplam Ltd. Testing laboratory

Page number: 1 Number of pages: 4

Republic of Bulgaria, Sofia,

www.termoplam.eu, e-mail: termoplam2011@abv.bq, GSM 0885 449 216

# TEST REPORT Nº133/11.01.2020

on the compliance of boilers series (range) COMBO: COMBO 25, COMBO 40 and COMBO 60 with the requirements of COMMISSION REGULATION (EU) 2015/1189 of 28 April 2015.


# **I. NAME AND SIGNATURE OF THE TESTED SAMPLE:**

Production series (range) COMBO: COMBO 25, COMBO 40 and COMBO 60.

## **II. NAME AND DESCRIPTION OF THE TESTED SAMPLE:**

Boiler models COMBO 25, COMBO 40 and COMBO 60 made of steel sheet metal by welding.

**III. LEGAL DOCUMENT:** COMMISSION REGULATION (EU) 2015/1189 of April 2015.



Picture of boilers

Page number: 2 Number of pages: 4

# **IV. QUANTITY OF THE TESTED SAMPLES:** Boiler models


COMBO: COMBO 25, COMBO 40 and COMBO 60 are randomly selected units of regular production of 1 each.

## **V. CUSTOMER:**

ABC PROIZVOD d.o.o; Miloša Obrenovića 2; 31000 Užice; R. Serbia.

**VI. PURPOSE AND OBJECT OF THE TASK:** Conformity assessment of the boilers COMBO: COMBO 25, COMBO 40 and COMBO 60 with the requirements of COMMISSION REGULATION (EU) 2015/1189 of 28 April 2015.

## **VII. TECHNICAL FEATURES**:



Scheme (drawing of the boilers)

Index: COMBO

# Termoplam Ltd. Sofia Testing laboratory

Page number: 3 Number of pages: 4

#### **VIII. TEST CONDITIONS:**

- 8.1. Working condition of the combustion device according to the requirements for tests at nominal output according to EN 303-5:2012.
- 8.2. Processing of results calculate according to normal physical conditions and at 10 % O<sub>2</sub>.
- 8.3. Used results from the Test Report № 91/16.05.2016 of Laboratory Termoplam, Sofia and Test protocol Nr. 155000024/314 dated 18 January 2016, issued by accredited test laboratory TSU PIESTANY, š.p. Slovak Republic.

## **IX. RESULTS FROM AND OBSERVATIONS**:

9.1. Seasonal space heating emissions:

Table 1

Results	Model boiler			In accordance REGULATION
Es	COMBO 25	COMBO 40	COMBO 60	(EU) 2015/1189 [mg/Nm³]
Dust [mg/Nm³]	20	33	36	[PM] ¹ ≤ 40
CO [mg/Nm³]	451	378	390	[CO] <sup>2</sup> ≤ 500
OGC [mg/Nm³]	8	17	18	[OGC] <sup>3</sup> ≤ 20
NO <sub>x</sub> [mg/Nm <sup>3</sup> ]	63	148	154	[NO <sub>x</sub> ] <sup>4</sup> ≤ 200

Dust content of exhaust gases [PM]  $^1 \le 40 \text{ mg/Nm}^3$  for for automatically stoked boilers in accordance with point 1 (c), of Annex II of the REGULATION (EU) 2015/1189.

CO of exhaust gases [CO]  $^2 \le 500 \text{ mg/Nm}^3$  for automatically stoked boilers in accordance with point 1 (e), of Annex II of the REGULATION (EU) 2015/1189.

OGC of exhaust gases [OGC]  $^3 \le 20 \text{ mg/Nm}^3$  for for automatically stoked boilers in accordance with point 1 (d), of Annex II of the REGULATION (EU) 2015/1189.

 $NO_x$  of exhaust gases  $[NO_x]^4 \le 200 \text{ mg/Nm}^3$  for biomass boilers in accordance with point 1 (f), of Annex II of the REGULATION (EU) 2015/1189.

9.2. Seasonal space heating energy efficiency:

Index: COMBO

# Termoplam Ltd. Sofia Testing laboratory

Page number: 4 Number of pages: 4

Table 2

Model boiler	Results	In accordance REGULATION
	ηs	(EU) 2015/1189.
	%	[%]
COMBO 25	79	[ ηs ] ¹ ≥ 77
COMBO 40	82	[ ηs] ¹ ≥ 77
COMBO 60	82	[ ηs] ¹ ≥ 77

#### Where:

- ηs % - the seasonal space heating energy efficiency:

[  $\eta s$  ]  $^1 \ge 77$  % for boilers with a rated heat output of more than 20 kW in accordance with point 1 (b), of Annex II of the REGULATION (EU) 2015/1189.

# X. CONCLUSION:

Boiler models COMBO 25, COMBO 40 and COMBO 60 is satisfying and fulfilling the requirements of REGULATION (EU) 2015/1189.

#### **XI. ENCLOSURES:**

- 10.1. Picture of boiler;
- 10.2. Assembly drawing of the sample.



11.01.2020

MANAGER: ..... (eng. Pl. Iliev)

#### **NOTE:**

The test results and conclusions relate only to the tested samples.

Extracts from the test report can't be reproduced without written agreement of the testing laboratory.

This document is only informative.